



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller




Fenster · windows
Rollläden · shutters
Türen + Tore · doors
Fassaden · curtain walling
Baubeschläge · building hardware

TEST CERTIFICATE NO. 19/02-A010-Z3


PfB-Internal-No. 2019-27-0500

Version 1.en

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A2 : 2016 "Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets- German version EN 14351-1:2006 + A2:2016"

Product type	Inward opening only turn single casement window, PVC, double glazing		
Product name	Superclass 81mm		
Hardware	Accado		
Sealing	TPV		
Dimension	Total outside dimensions (W x H)	max. 900 mm x 1200 mm	
Classification	According to test report No. 19/02-A010-B3 from April 24, 2019:		
	 EN 1026	Air Permeability	EN 12207 Class 4
	 EN 1027	Water tightness	EN 12208 Class 8A
	 EN 12211	Resistance to wind load	EN 12210 Class C5/B5

Validity Period of validity of EN 14351-1 : 2006 + A2 : 2016


Dipl.-Ing. (FH) Rüdiger Müller
Head of Institute



Stephanskirchen
April 24, 2019


Yiğit Altuğ
Responsible Official

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
AG Traunstein HRA 8871
Lackermannweg 24, 83071 Stephanskirchen
phG PfB Verwaltungs GmbH
Geschäftsführer: Matthias Demmel, Rüdiger Müller
AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 674947 0
Telefax +49 (0) 80 36 / 674947 28
www.pfb-rosenheim.de
info@pfb-rosenheim.de

Sparkasse Rosenheim-Bad Aibling
IBAN: DE88 7115 0000 0500 5567 41
SWIFT-BIC: BYLADEM1R0S
Steuer-Nr.: 156/172/13009
USt-IdNr.: DE245353602

